

CERTIFICATE OF APPROVAL No CS 5059

This is to certify that, in accordance with
STS200 General Requirements for Certification of Enhanced Security Products
The undermentioned products of

JELD-WEN (UK) LTD

Retford Road, Woodhouse Mill, Sheffield, S13 9WH
Tel: 0114 254 2000

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

44mm Securefit PAS24 Timber Doorset
(With Flush and Moulded Facings).
Laminated Core.

TECHNICAL SCHEDULE


STS201 - Enhanced security
requirements for doorsets to satisfy
the requirements of PAS24 (with Fire
performance)

CLASSIFICATION

Security	Weather	Strength	Material Specific	Fire *
PAS24 D	BS6375-1 800U	BS6375-2 Medium Duty	BS644	BS476:PT22 FD30
Fire performance certified to TS10 under CERTIFIRE certificate CF 5965				

NPD = No performance determined

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited



Paul Duggan
Certification Manager



Issued: 23rd October 2001
Revised: 25th January 2022
Valid to: 9th June 2026



CERTIFICATE No CS 5059 JELD-WEN (UK) LTD

JELD-WEN (UK) LTD – 44mm Securefit PAS24 Timber Doorset (With Flush and Moulded Facings). Laminated Core.

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. This approval relates to the use of the above in providing an enhanced security performance to PAS24:2016 Annex A & B, a weather performance of 800U to BS6375-1:2015, a mechanical strength performance of Medium Duty to BS6375-2:2009, an additional performance to BS6375-3:2009 Annex A & C, and a fire resistance performance of 30 minutes integrity and 30 minutes insulation as defined in BS 476: Part 22: 1987 and CERTIFIRE approved in accordance with TS10 under certificate CF 5965.
3. The doorsets are approved on the basis of:
 - i. Initial type testing against PAS24 & BS6375. Element Wednesbury test reports WIL 339311, WIL 324214, WIL 400005, WIL 380930, WIL 419084, WIL 419085, WIL 419086, WIL 436790, WIL 438151, WIL 432963-1, WIL 432964, WIL 432965 & WIL 432966.
 - ii. Audit testing at the frequency specified in STS 200 & STS 201 where relevant.
 - iii. A design appraisal against STS201 where relevant.
 - iv. Inspection and surveillance of factory production control at Retford Road, Woodhouse Mill, Sheffield, S13 9WH and Snow Hill, Melton Mowbray, LE13 1PD.
4. This approval is applicable to complete doorsets only.
5. This certification is designed to demonstrate compliance of the doorset specifically with PAS24, TS10 and the requirements of Secured by Design. If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
6. This approval is applicable to single-leaf, unglazed, open-in or open-out doorsets with or without coupled sidelights & toplights with or without letterplates at leaf & frame dimensions up to those given in Table 1 & Table 2.

certisecure

CERTIFICATE No CS 5059 JELD-WEN (UK) LTD

JELD-WEN (UK) LTD – 44mm Securefit PAS24 Timber Doorset (With Flush and Moulded Facings). Laminated Core.

7. Approved hardware items are:
- 3no. JELD-WEN branded Cooke Brothers Grade 13 hinge 7730 (open-in or open out) or 3no. Zoo Hardware Grade 13 hinges ZHSS243 range (open-in only)
 - Fullex Crimebeater SL16 lock (open-in only) or
 - ERA Invincible MPL with centre hook 6935-3H-609-79ZA (ERA branded) & 6935-3H-629-79ZJ (JELD-WEN (open-in or open-out) or
ERA Invincible MPL with centre deadbolt 6945-INV-609-79ZA (open-in or open-out)
 - Eurospec/Carlisle Brass TS007 1* MPX6 KM585549 double key & thumbturn cylinders or
ERA Fortress TS007 3* KM553031 double key & thumbturn cylinders
 - Mila Prosecure TS007 2* handle or
ERA / Fab & Fix Balmoral handle (with 3* cylinder only)
 - UAP The Soterian TS008 FD30 letterplate KM670828
 - Briton 2400 Series transom mount concealed closer 2420T
 - UK Fixings Ltd Spy Viewer 22528 or ERA Spy viewer 35053 6V254 / 35054 6V253
 - Lorient Acoustic Drop Seal LAS8001SI
 - Lorient Threshold Plate LAS4015 or LAS4002

For the full specification of the product please refer to the constructional specification that accompanies this certificate.

Page 3 of 5 Signed
E/128, E/365

Issued: 23rd October 2001
Revised: 25th January 2022
Valid to: 9th June 2026

CERTIFICATE No CS 5059 JELD-WEN (UK) LTD

JELD-WEN (UK) LTD – 44mm Securefit PAS24 Timber Doorset (With Flush and Moulded Facings). Laminated Core.

Configuration	Maximum door leaf width (mm)	Maximum door leaf height (mm)	Door leaf thickness (mm)
Open-in, single leaf	926	2040	44
Open-out, single leaf (Cooke Brothers hinge and ERA Invincible lock only)	926	2040	44

Table 1. Permitted Door Leaf Dimensions

Configuration	Maximum frame width (mm)	Maximum frame height (mm)
Single leaf without toplights & sidelights (frame option 1, 2 or 3)	1018	2108
Single leaf with toplights & sidelights * (frame option 3)	2600	2600

Table 2. Permitted Frame Dimensions

* ensuring maximum leaf & glass sizes are not exceeded.

Note: Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTISECURE approval.

- The doorset shall be mechanically fixed to wall constructions having a fire resistance of at least 30 minutes as specified in the Data Sheet, ensuring frame jambs are fixed through to the wall at not less than four points with steel or nylon fixings at maximum 600 mm centres penetrating the wall to at least 50 mm and installed as stated within BS 8214 and the manufacturers approved installation instructions accordingly.

The bottom edge of the door leaf may be trimmed without limit, providing door to threshold gaps specified are not be exceeded. Top and vertical leaf edges shall not be trimmed.



CERTIFICATE No CS 5059
JELD-WEN (UK) LTD

JELD-WEN (UK) LTD – 44mm Securefit PAS24 Timber Doorset (With Flush and Moulded Facings). Laminated Core.

9. Labels to the CERTIFIRE/CERTISECURE design referencing CERTIFIRE, CERTISECURE, FD30, PAS24 D, JELD-WEN (UK) Ltd, CERTISECURE certificate No. CS 5059 and CERTIFIRE certificate No. CF 5965 shall be affixed to each doorset in the prescribed position.
10. This approval relates to on going production. The doorset and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTISECURE name and mark together with the CERTISECURE Certificate number and application where appropriate.

Further Information

Further information regarding the details contained in this report may be obtained from JELD-WEN (UK) Ltd, Retford Road, Woodhouse Mill, Sheffield, South Yorkshire, S13 9WH (Tel: 0114 229 3250, Fax: 0114 254 2000)

Further information regarding CERTISECURE & CERTIFIRE certification and other approved products can be obtained from Warringtonfire Testing and Certification Limited, Holmesfield Road, Warrington WA1 2DS (Tel: 01925 646 777)