



CERTIFICATE OF APPROVAL

No CF 534

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

HALSPAN LIMITED

Regent House, Regent Centre,
Linlithgow, West Lothian, EH49 7HU
Tel: 03300563836

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

Halspan Limited FD30 Optima
Timber Door Assemblies

TECHNICAL SCHEDULE

TS10 Fire Resisting Door
Assemblies with Non
Metallic Leaves

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager



Issued: 1st February 2007
Reissued: 6th March 2023
Valid to: 5th March 2028





CERTIFICATE No CF 534 HALSPAN LIMITED

HALSPAN LIMITED OPTIMA FD30 TIMBER DOOR ASSEMBLIES

This approval relates to the use of the above doors in providing fire resistance of 30 minutes integrity as defined in BS 476: Part 22. Subject to the undermentioned conditions, the doors would be expected to meet the relevant requirements of BS 9999 for FD30 door assemblies when used in accordance with the provisions therein.

1. This certification is provided to the client for their own purposes, and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. The doors are approved on the basis of:
 - i) Initial type testing
 - ii) A design appraisal against TS10
 - iii) Inspection and surveillance of factory production control
 - iv) Certification under a CERTIFIRE approved Quality Management System
 - v) Audit testing in accordance with TS10
3. The doors comprise cellulosic cored leaves in various finishes for use with timber, mild steel or aluminium frames, with intumescent edge seals (ITT & ITM FD30).
4. This approval is applicable to both complete door assemblies and door leaves. Where the door is not supplied in a fully fitted form it is a condition of this approval that an agreed Data Sheet accompanies the product and is complied with in its entirety. Failure to do so will invalidate this approval and may jeopardise the fire performance of the door.
5. This approval is applicable to latched and unlatched, single and double-acting, single and double-leaf, ITT and ITM assemblies with or without overpanels, at leaf dimensions up to those given in Table 1 below:
6. Glazing shall only be undertaken by the door manufacturer, or a CERTIFIRE approved Licensed Door Processor, and shall be in accordance with the Data Information Sheet and Construction Specification. No site cutting or glazing of apertures is permitted.
7. Hardware items, including closing devices and intumescent fire seals, shall be as specified in the Data Sheet.
8. The door assembly shall be mechanically fixed to wall constructions having a fire resistance of at least 30 minutes.

Page 2 of 3 Signed
C/079

Issued: 1st February 2007
Reissued: 6th March 2023
Valid to: 5th March 2028

CERTIFICATE No CF 534 HALSPAN LIMITED

HALSPAN LIMITED OPTIMA FD30 TIMBER DOOR ASSEMBLIES

9. Labels to the CERTIFIRE design, or approved by CERTIFIRE, referencing CERTIFIRE and CERTIFIRE Ref. No. CF534 and FD30 classifications resistance shall be affixed to each door in the prescribed position.
10. This approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application when appropriate.

Door assembly configuration	Maximum Height (mm)	Maximum Width (mm)	Area (m ²)
Single-Acting, Single-Leaf Latched / Unlatched Timber Frame	3200 (at 836 wide)	1086 (at 2700 high)	2.93
Single-Acting, Double-Leaf Latched / Unlatched Timber Frame	2630 (at 915 wide)	1165 (at 2130 high)	2.48
Double-Acting, Single-Leaf Latched / Unlatched Timber Frame	3264 (at 921 wide)	1171 (at 2764 high)	3.01
Double-Acting, Double-Leaf Latched / Unlatched Timber Frame	3264 (at 921 wide)	1171 (at 2764 high)	3.01
Single-Acting, Single-Leaf Latched / Unlatched Mild Steel Frame	2542 (at 826 wide)	1076 (at 2042 high)	2.20
Single-Acting, Double-Leaf Latched / Unlatched Mild Steel Frame	2542 (at 826 wide)	1076 (at 2042 high)	2.20
Single-Acting, Single-Leaf Latched / Unlatched Aluminium Frame	2700 (at 838 wide)	838 (at 2700 high)	2.26
Single-Acting, Double-Leaf Latched / Unlatched Aluminium Frame	2700 (at 838 wide)	838 (at 2700 high)	2.26

Table 1

Note: Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTIFIRE approval.

HALSPAN LIMITED OPTIMA FD30 TIMBER DOOR ASSEMBLIES CF 534 DATA SHEET

1. General

This door leaf has been fire tested and is certified by CERTIFIRE as being capable of providing fire resistance of 30 minutes integrity as defined in BS 476: Part 22, when installed in accordance with the following conditions. Subject to these, the door will meet the relevant requirements of BS 9999 for FD30 when used in accordance with the provisions therein.

In recognition of this, the leaf carries a prefixed label on the top or hanging edge of the door, issued under the terms of the CERTIFIRE scheme. This label uniquely identifies the door leaf, the manufacture of which complies with a CERTIFIRE approved Quality Management System and is subject to on-going surveillance. This label shall not be removed.

It is emphasised that the certification is conditional upon the following instructions being complied with in their entirety. Failure to do so will invalidate this approval and may jeopardise the fire performance of the door. Door assemblies supplied pre-fitted with components by Halspan Limited may be considered to meet the requirements in respect of those items.

2. Door Leaf Dimensions

This approval is applicable to single and double-action, single and double-leaf, latched and unlatched, assemblies at leaf dimensions up to those detailed within Table 1 below.

Door assembly configuration	Max. Height (mm)	Max. Width (mm)	Max. Area (m²)
Single-Acting, Single-Leaf Latched / Unlatched Timber Frame	3200 (at 836 wide)	1086 (at 2700 high)	2.93
Single-Acting, Double-Leaf Latched / Unlatched Timber Frame	2630 (at 915 wide)	1165 (at 2130 high)	2.48
Double-Acting, Single-Leaf Latched / Unlatched Timber Frame	3264 (at 921 wide)	1171 (at 2764 high)	3.01
Double-Acting, Double-Leaf Latched / Unlatched Timber Frame	3264 (at 921 wide)	1171 (at 2764 high)	3.01
Single-Acting, Single-Leaf Latched / Unlatched Mild Steel Frame	2542 (at 826 wide)	1076 (at 2042 high)	2.20
Single-Acting, Double-Leaf Latched / Unlatched Mild Steel Frame	2542 (at 826 wide)	1076 (at 2042 high)	2.20
Single-Acting, Single-Leaf Latched / Unlatched Aluminium Frame	2700 (at 838 wide)	838 (at 2700 high)	2.26
Single-Acting, Double-Leaf Latched / Unlatched Aluminium Frame	2700 (at 838 wide)	838 (at 2700 high)	2.26

Table 1

Under no circumstances must the maximum height, maximum width or maximum area be exceeded without separate CERTIFIRE approval.

All timber framed door assembly configurations may incorporate overpanels which include a transom rail as detailed within data sheet.

All single-acting timber framed door assembly configurations may incorporate overpanels without a transom rail as detailed within data sheet.

3. Door Frame

To be any of the following:-

Softwood or Hardwood (single acting doorsets) Excluding Ash & Iroko	i) Density:	450 kg/m ³ min.
	ii) Dimensions:	70 mm by 28 mm min.
	iii) Door Stop:	12 mm deep pinned, screwed, or rebated from solid (min stop density 450 kg/m ³). Where the stop is rebated from solid the overall frame thickness must be increased by 12 mm to accommodate the 12 mm rebate depth.
MDF (single acting doorsets)	i) Density:	730 kg/m ³ min.
	ii) Dimensions:	70 mm by 28 mm min.
	iii) Door Stop:	12 mm deep pinned, screwed, or rebated from solid (min stop density 730 kg/m ³). Where the stop is rebated from solid the overall frame thickness must be increased by 12 mm to accommodate the 12 mm rebate depth.
Softwood or Hardwood (double acting doorsets) Excluding Ash & Iroko	i) Density:	450 kg/m ³ min.
	ii) Dimensions:	70 mm by 28 mm min.
MDF (double acting doorsets)	i) Density:	730 kg/m ³ min.
	ii) Dimensions:	70 mm by 30 mm min.
Mild Steel (hollow or backfilled with sand / cement mortar)	i) Dimensions	95 mm by 30 mm minimum 250 mm by 60 mm maximum Frame to include a 15 mm integral stop Frame to be manufactured from 2 mm thick steel.
Aluminium (Single leaf assemblies)	i) Type	'Unity' 3 piece frame fixed directly to the supporting construction
	ii) Dimensions	63.5 mm by 31.75 mm Frame to include a 15 mm integral stop. Frame to be manufactured from 0.9 mm extruded aluminium.
Aluminium (Double leaf assemblies)	i) Type	Frame fixed around a hardwood sub-frame with a minimum density 660 kg/m ³ .
	ii) Dimensions	87 mm by 20 mm (sub-frame)
Jointing:	Butt joints, mortice and tenon, mitred or half lapped joints with the head screw fixed to the jambs using two steel screws	
Door to frame gaps:	Not to exceed 4 mm except at threshold where up to 8 mm is permitted and 3.5 mm at the meeting stiles	

4. Overpanels / Sidepanels

Overpanels and sidepanels shall be manufactured to the same specification as the door leaves.

Flush overpanels may be included up to a maximum height of 1000 mm and shall include 6 mm thick hardwood lippings (minimum) and opposing lipping to the leaf head, or a rebated 18 mm thick (minimum) hardwood lipping with 22 mm wide by 12 mm deep rebate at the bottom edge, with a corresponding 18 mm thick (minimum) hardwood lipping with a 22 mm wide by 12 mm deep rebate in the top edge of the leaf.

Flush overpanels shall be fixed using steel screws at a maximum of 400 mm centres and a maximum of 100 mm from each corner, through centre of panel to a depth of at least 30 mm

Where rebated meeting edges are not incorporated on double leaf assemblies, timber astragals (min 640kg/m³) are required at the junction between the bottom of the overpanel and the top edge of the doors.

Overpanels incorporating a transom rail 28 mm thick (minimum), may be included up to a maximum size of 1500 mm high

Sidepanels incorporating a mullion rail 28 mm thick (minimum), may be included up to a maximum width of 1000 mm.

Overpanels / Sidepanels shall be bedded against beads or the stop of the rebate and be screw fixed at minimum 400 mm centres, maximum 100 mm from each corner through the centre of the panel to a depth of at least 30 mm.

Overpanels will include an identical intumescent specification to the door leaves.

Double-action door assemblies complete with overpanels shall incorporate a transom rail.

5. Glazed Fanlights and Sidelights

Any CERTIFIRE approved glazing systems may be used providing the specification and installation details given in the appropriate certification documents are adhered to.

6. Supporting Construction

The door assemblies are approved to be installed in brick, block, masonry, timber or steel stud supporting constructions of minimum overall thickness 70 mm, providing at least 30 minutes fire resistance. Where stud partitions are used these should be suitably constructed to provide a secure fixing for the door assemblies as recommended by the partition manufacturer.

Where stud partitions are used these should be suitably constructed to provide a secure fixing for the door assemblies as recommended by the partition manufacturer.

Where brick, block, masonry walls are plasterboard faced, the plasterboard adjacent to the door assembly shall be mechanically fixed to ensure that it remains in-situ for the required integrity period.

7. Installation

The opening may be lined with softwood or hardwood which shall be continuous and of minimum width, 70mm. Each door frame jamb to be fixed through to the wall at not less than four points with steel or nylon fixings at maximum 600 mm centres penetrating the wall to at least 50 mm. Timber based architraves are optional with no restrictions on material, size or fixing.

Door assemblies shall be installed as stated in BS 8214. Suitable CERTIFIRE approved lineal gap sealing systems may also be utilised to protect the frame/supporting construction gap, subject to the conditions contained within the relevant certificate.

The use of third party accredited installers provides a means of ensuring that installations have been conducted by knowledgeable contractors, to appropriate standards, thereby increasing the reliability of the anticipated performance in fire.

Door leaves may be trimmed to fit the frame by the following maximum amounts:

- Stiles (each): 3 mm
- Top: 3 mm
- Bottom: No limit providing bottom lippings are not fitted.
3 mm if bottom lipping is fitted.

Note that the maximum door to frame and door to threshold gaps specified shall not be exceeded, nor shall the door edge fitted with the CERTIFIRE label be trimmed since removal of the label will invalidate the certification.

The labelled edge may be subjected to minor 'shooting-in', providing the label is not damaged or removed in the process, and the amount of material removed does not exceed that stated previously.

8. Lippings

Hardwood	i) Density:	650 kg/m ³ minimum
	ii) Thickness:	Minimum 6 mm Maximum 25 mm
	iii) Adhesive:	Polyurethane based hot melt adhesive, PVA, Cascamite or Urea Formaldehyde
Notes:	All doors, must be lipped to the vertical edges as a minimum with the option to apply lippings to the top and bottom leaf edges,	

9. Glazed Apertures

All apertures to be factory prepared by Halspan Limited, or a CERTIFIRE approved Licensed Door Processor. No site cutting of apertures permitted as this will invalidate the certification.

Doors may incorporate CERTIFIRE approved glazing systems subject to the conditions contained within the relevant CERTIFIRE certificate (e.g., maximum size associated with glass, system, edge cover, aperture lining requirements, etc.) and the maximum pane dimensions given below (whichever is smaller):

Aperture dimensions: Doors may incorporate one or more vision panels to the maximum sizes identified in the table below:

Area: Maximum total glazed area of 1.22 m² per leaf

Margins: 100 mm from the perimeter edge, 100 mm between apertures

Maximum Permitted Aperture Dimensions		
Max. Height (mm)	Max. Width (mm)	Max. Area (m ²)
1972 (at 619 wide)	800 (at 1525 high)	1.22

Hardwood or non-combustible setting blocks will be used to establish the correct edge cover.

Double-leaf door assemblies with equal width leaves shall both be similarly glazed.

10. Intumescent Seals

CERTIFIRE certificated intumescent seals are required to be fitted to these doors as below.

For door assemblies to BS476: Part 22 – classified as FD30 – Timber frames

Door assembly Configuration*	Frame material	Position	Required Intumescent Protection
Single-acting, Single-leaf door assemblies latched / unlatched Max 2410 mm high and 1033 mm wide (Max 2.2m ²)	Timber	Head	Single 10 mm wide by 4 mm thick ISL Therm-A-Seal
		Vertical edges	Single 10 mm wide by 4 mm thick ISL Therm-A-Seal
Single-acting, Single-leaf door assemblies latched / unlatched Max 3200 mm high and 1086 mm wide (Max 2.93m ²)	Timber	Head	Single 20 mm wide by 4 mm thick ISL Therm-A-Seal
		Vertical edges	Single 10 mm wide by 4 mm thick ISL Therm-A-Seal
Single-acting, double-leaf door assemblies latched / unlatched	Timber	Head	Single 10 mm by 4 mm thick Lorient LP1004
		Hanging edges	Single 10 mm by 4 mm thick Lorient LP1004
		Meeting edges	Single 10 mm by 4 mm thick Lorient LP1004 in each meeting edge (opposing)
Double-acting, Single-leaf door assemblies latched / unlatched	Timber	Head	Single 15 mm by 4 mm thick Lorient LP1504
		Vertical edges	Single 10 mm by 4 mm thick Lorient LP1004
Double-acting, Double-leaf door assemblies latched / unlatched	Timber	Head	Single 15 mm by 4 mm thick Lorient LP1504
		Vertical edges	Single 10 mm by 4 mm thick Lorient LP1004
		Meeting edges	Single 10 mm by 4 mm thick Lorient LP1004 in each meeting edge (opposing)

For door assemblies to BS476: Part 22 – classified as FD30 – Timber frames & Overpanels

Door assembly Configuration*	Frame material	Position	Required Intumescent Protection
Single-acting, Single & Double-leaf door assemblies latched / unlatched Rebated Overpanel	Timber	Overpanel rebate	Single 10 mm wide by 4 mm thick ISL Therm-A-Seal
		Door rebate	Single 10 mm wide by 4 mm thick ISL Therm-A-Seal
Single & Double-acting, Single & Double-leaf door assemblies latched / unlatched Flush Overpanel	Timber	Bottom of overpanel	Single 15 mm wide by 4 mm thick Lorient LP1504
		Top edge of door	'Head' intumescent as specified in the Timber frame intumescent table.

For door assemblies to BS476: Part 22 – classified as FD30 – Steel frames

Door assembly Configuration*	Frame material	Position	Required Intumescent Protection
Single-acting, Single-leaf door assemblies latched / unlatched	Steel (hollow)	Head (door)	Single 20 mm wide by 4 mm thick Lorient LP2004 backed with a sheet of ISL Therm-A-Flex 20 mm wide by 2 mm thick.
		Vertical edges (door)	Single 20 mm wide by 4 mm thick Lorient LP2004 backed with a sheet of ISL Therm-A-Flex 20 mm wide by 2 mm thick.
Single-acting, double-leaf door assemblies latched / unlatched	Steel (hollow)	Head (door)	Single 20 mm wide by 4 mm thick Lorient LP2004 backed with a sheet of ISL Therm-A-Flex 20 mm wide by 2 mm thick.
		Hanging edges (door)	Single 20 mm wide by 4 mm thick Lorient LP2004 backed with a sheet of ISL Therm-A-Flex 20 mm wide by 2 mm thick.
		Meeting edges	Single 20 mm by 4 mm thick ISL Therm-A-Seal fitted to the edge of one leaf only
Single-acting, single-leaf door assemblies latched / unlatched	Steel (backfilled)	Head	Single 20 mm by 4 mm thick ISL Therm-A-Seal
		Vertical edges	Single 20 mm by 4 mm thick ISL Therm-A-Seal
Single-acting, double-leaf door assemblies latched / unlatched	Steel (backfilled)	Head	Single 20 mm by 4 mm thick ISL Therm-A-Seal
		Hanging edge	Single 20 mm by 4 mm thick ISL Therm-A-Seal
		Meeting edge	Single 10 mm by 4 mm thick ISL Therm-A-Seal & a single 10 mm by 4 mm thick ISL Therm-A-Stop fitted into the edge of one leaf only.

For door assemblies to BS476: Part 22 – classified as FD30 – Aluminium frames

Door assembly Configuration*	Frame material	Position	Required Intumescent Protection
Single-acting, single-leaf door assemblies latched	Aluminium	Head	Single 25 mm by 2 mm thick ISL Therm-a-Strip fitted fitted at mid-width of the door leaf within the frame reveal.
		Vertical edges	Single 25 mm by 2 mm thick ISL Therm-a-Strip fitted fitted at mid-width of the door leaf within the frame reveal.
Single-acting, double-leaf door assemblies latched / unlatched	Aluminium	Head (door)	Single 30 mm by 4 mm thick ISL Therm-A-Seal
		Hanging edge (door)	Single 20 mm by 4 mm thick ISL Therm-A-Seal
		Meeting edge	2No. 10 mm by 4 mm thick ISL Therm-A-Seal positioned centrally, 8 mm apart within one door leaf edge.

*See Table 1 for size restrictions

Latched or unlatched, single acting, single-leaves with maximum leaf dimensions 2040 mm high by 926 mm wide and of a minimum thickness of 43 mm may utilise alternative Intumescent in-line with the relevant CERTIFIRE approval for the proposed intumescent seal.

All seals to be CERTIFIRE approved to Technical Schedule 35.

All other door assembly configurations should include the specific intumescent size type and location as specified within the data sheet.

Smoke seals may be included subject to the conditions contained within the relevant CERTIFIRE certificate for the smoke seal.

11. Hinges

Hinges shall be CE marked against EN 1935 for use on 30 minute timber fire door assemblies.

Number:	Minimum 3 No. hinges	
Type:	Steel lift off or butt hinges.	
Positions:*	Top Hinge:	Max 150 mm from the top of door to top hinge.
	Middle Hinge:	Middle hinge fitted centrally in the leaf height.
	Bottom.	Max 250 mm from the bottom of door to bottom hinge
Dimensions:	blade height:	104 mm (+/- 20%)
	Blade width:	32 mm (+/- 3 mm)
	Thickness:	3 mm (+/- 0.5 mm)
	Knuckle dia.:	12 mm (+/- 2 mm)
Fixings:	Quantity:	4No. steel screws (minimum)
	Size:	No.8 by 32 mm long (minimum).
Intumescent Protection**	None required	

* The datum in all cases is the centreline of the hinge.

** The hinge specification above overrides any requirement for additional intumescent identified in the hinge manufacturer's certification providing the hinge specification falls within the parameters identified in the table above, specifically maximum dimensions and material.

Any other CERTIFIRE approved hinge may be fitted, providing the hinge dimension are no greater than 10% in blade width and 25% in blade height from that approved in the table above (excluding the tolerances stated). Where the Certifire approved hinge exceeds the specification given in the table above, the minimum requirement for intumescent protection to the hinges, by-passing perimeter intumescent, and the material density and thickness for the door and frame elements given in the hinge manufacture's CERTIFIRE certificate shall apply.

12. Locks and Latches

Locks / latches are not necessary. When fitted locks / latches shall be CE Marked for use on 30 minute timber fire doors.

Mortice type, automatic (sprung) latch bolt.

Max. case dimension:	100 mm high by 75 mm deep by 23 mm wide
Max. forend dimension:	150 mm high by 20 mm wide
Max. keep dimension:	150 mm high by 20 mm wide (excluding latch plate)
Latchbolt material:	Steel or material with a melting point greater than or equal to 950°C
Position:	Max. 1100 mm from bottom of door to centreline of spindle
Intumescent protection*	Latch cases, forend and strike plate to be bedded onto 1 mm of Interdens intumescent sheet material.

* The lock specification above overrides any requirement for additional intumescent identified in the lock manufacturer's certification providing the lock/latch specification falls within the parameters identified in the table above, specifically maximum dimensions and material.

Any other CERTIFIRE approved lock/latch may be fitted, providing no lock/strikeplate dimension is more than 25% of that approved in the table above and subject to the conditions contained within the relevant certificate. Where the Certifire approved lock/latch exceeds the specification given in the table above, the minimum requirement for intumescent protection to the locks, latches and strikeplates, by-passing perimeter intumescent, and the material density and thickness for the door and frame elements given in the lock/latch manufacture's CERTIFIRE certificate shall apply.

- Recessing for locks shall result in a tight fit, allowing for the intumescent protection specified.
- No restriction on type and material of face fixed mechanical lever handles and knobs providing these are wholly surface mounted (with the exception of the spindle and fixing holes) and the spindle hole is a maximum 15 mm in diameter.
- The Euro profile cylinder recess in the door face shall follow the shape of the cylinder and result in a tight fit.
- The use of oval profile cylinders is not permitted.

13. Self-Closing Devices

All doors are required to be fitted with a CERTIFIRE certificated self-closing device. The exceptions are doors kept locked shut such as service access doors. Note: closers with mechanical hold-open mechanisms are not permitted to be used. Building Regulations may identify locations within domestic locations where self-closing devices are not mandatory.

The closers shall have a power rating appropriate to the leaf sizes, subject to the closer having the ability to close the door from any angle and against any latch and/ or seals fitted.

The closer shall have the ability to provide a minimum size 3 closing force. Where doors are unlatched a minimum size 3 shall be maintained.

Closers shall be CE Marked against EN 1154 and categorised as grade 1 – suitable for use on fire / smoke door assemblies.

13a Surface mounted overhead closers

Any CERTIFIRE approved surface mounted overhead closer may be fitted, subject to the conditions contained within the relevant certificate.

13b Transom Mounted and Concealed Closers

Not permitted

13c Double-Action Floor Springs

Top pivot dimensions:	Door portion:	122 mm long x 15 mm deep x 29 mm wide
	Frame portion:	165 mm long x 37 mm deep x 25 mm wide
Bottom arm dimensions:	Maximum 235 mm long x 20 mm deep x 24 mm wide	
Material:	Steel	
Intumescent: protection*	Top pivot:	2 mm Interdens or 2 mm graphite intumescent sheet material to base and sides of top pivot (door and frame portions).
	Bottom arm:	None required

14. Ancillary items

Please note that hardware items other than those discussed within this certificate of approval are not permitted.

14a **Protection plates and signage**

Surface mounted plastic, steel, aluminium or brass plates are acceptable on the basis that they are:

- Maximum 2mm thick.
- Do not occupy more than 20% of the door leaf in total or exceed 500mm in height for kickplates and 300mm for mid-plates, whichever is the smaller.
- Do not wrap around the vertical edges, and on the closing face do not extend beneath the door stops (generally 40-50mm narrower than door width)
- Plates/signage can be bonded with a thermally softening adhesive. Additionally, screws may be used.

14b **Flushbolts**

Not permitted

14c **Door Viewers**

Not permitted

14d Pull Handles

Screw-fixed, bolt-fixed from the back and back-to-back fixed pull handles of steel, brass, aluminium and nylon coated are permitted providing any through-bolt fixings are of steel and maximum bolt to bolt centres do not exceed 1000 mm.

A maximum 15 mm diameter recess is permitted for through bolt fixings.

Bolt through fixings will require intumescent protection in the form of a 1 mm thick graphite tube, or Intumescent mastic to the full depth of the recess.

14e Air transfer grilles

No site cutting of apertures permitted as this will invalidate the certification.

Where apertures are pre-cut by Halspan Limited, or a CERTIFIRE approved Licensed Door Processor, Intumescent Air Transfer Grilles may be fitted on site by NON-CERTIFIRE approved staff, however, the Intumescent Air Transfer Grilles shall be CERTIFIRE approved for use in FD30 timber based doors. The air transfer grilles must be fitted into apertures prepared in line with the relevant CERTIFIRE certificate for the air transfer grille. Care must be taken to ensure all fitting instructions are followed, including any constraints imposed by the CERTIFIRE certificate with regards to position of the air transfer grille within the door assembly.

14f Letter Plates

Where letter plates are fitted, the aperture for a letter plate may be formed on site by NON-CERTIFIRE approved staff, however, the letter plates shall be CERTIFIRE approved for use in FD30 timber based doors. The letter plates must be fitted into apertures prepared in line with the relevant CERTIFIRE certificate for the letter plate. Care must be taken to ensure all fitting instructions are followed, including any constraints imposed by the CERTIFIRE certificate with regards to position of the letter plate within the door assembly.

14g Dropseals

Dropseals shall be CERTIFIRE approved and wholly surface mounted.

The use of recessed dropseals is not permitted.

14h Coat Hooks and Other Surface Mounted Hardware

Ancillary items which are wholly surface mounted may be fitted providing:

- These items are screw fixed or bonded only.
- Are not bolted through the full thickness of the door.
- Are not directly above, or closer than 100 mm to any non-insulated glazing.

14i. Electric Strikes / Electromechanical locks

Not permitted

15. Further Information

Further information regarding the details contained in this data sheet may be obtained from Halspan Limited (Tel: 01506 827538).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from Warringtonfire Testing and Certification Limited (Tel: +44 (0) 1925 646777).